

BEST PRACTICE

LOCATION:	Cement plant	ARTICLE YEAR	2017
ACTIVITY:	Maintenance & Housekeeping	COMPANY:	Aggregate Industries
SUB ACTIVITY:	N/A	COMPANY LOCATION:	Cauldon Cement
BEST PRACTICE No:	BP1986	COMPANY TEL:	07966 801931
COUNTRY OF ORIGIN:	United Kingdom		

TITLE

Safe removal of meal chutes – Cauldon Cement

ARTICLE

DESCRIPTION

During the major shutdown periods at Cauldon Cement works maintenance is carried out to the cyclones, chutes, pipes and flaps within the pre-heater tower. The maintenance work can produce large amounts of demolished refractory materials, cyclone clean down material and also new refractory materials (known as rebounds). The material is caught by blanks inserted into the pipework before the demolition process starts. Once the process is complete, the blanks are removed and any blockages and waste material removed from the meal chutes and flaps prior to restarting the plant. This could require the meal chutes and flaps to be removed which required the use of lifting equipment, slinging and rigging. This was identified by the shutdown team as a high risk activity.

Following a brainstorming session, it was decided to create a new hinge system that would enable a section of the feedpipe to be removed. A trolley that utilised a hydraulic ram and pumps was used to lift the flap sections and allow them to be rolled out of the way of the cyclones and any material dropping down from the cyclones. Once the chutes and flaps were moved, a purpose built hopper was installed at the bottom of the meal chutes. The hopper directed material into a wheeled skip which was used to catch and then remove the waste.

BENEFITS

- Hinges and flaps can be removed with relative ease
- Safer without the requirement for slinging and rigging
- Reduced manual handling
- Reduced risk of operators being hit by falling material
- Shut down activities can be started earlier as hinge system easily operated
- Cleaner operation as material directed into skips

ARTICLE IMAGES

Click image to enlarge



Click image to enlarge

