

INCIDENT ALERT

INCIDENT TIME: Out of hours weekend/bank holiday
COUNTY: Gloucestershire
INCIDENT No: 00002

DATE: 22/03/2012
LOCATION: Rural

Shorcote Quarry

INCIDENT DETAILS

Criminals accessed the site with a vehicle across adjoining land and by cutting the perimeter fencing. The electricity sub-station was broken into and power was disabled. Ground cables to pumps in the limestone and dewatering areas were then exposed and it is believed attached to the vehicle and dragged out of the ground. Replacement and installation of new cables £8k

POLICE REACTION

Police attended site with a forensics team

HEALTH AND SAFETY IMPLICATIONS

Electrocution

LEARNING POINTS

Frequency of perimeter security checks increased Discussions held with neighbouring landowner on access issue and site security of adjoining land.

IMAGES